

### Description

The ProLon T500 digital sensor is designed to work with a variety of ProLon controllers, to which it transmits information such as the ambient zone temperature, heating and cooling setpoints as well as the schedule override request from the zone. The T500 has backlit graphical LCD display and a knob mounted on an precision rotary encoder with incremental feedback.



### Features

- Circular knob and graphical display, which allow simple and intuitive control
- Infinitely turning rotary encoder with incremental detents (mechanical feedback) allows for precise setpoint adjustment
- Designed to work with various ProLon C1000 and VC2000 series controllers, sending them zone temperature, setpoints and schedule override request
- Easy wiring with numbered screw type terminal block or RJ45 modular jack
- Oval-shaped screen and curved features offer a modern look. Other colors available!

### Technical specifications

Supply: 24 VAC  $\pm 10\%$ , 50/60 Hz

Consumption: 5 VA max

Inputs: None

Outputs: None

Screen: LCD 80x130 pixels with backlighting

Interface: Knob mounted on rotary encoder with detents and schedule override push-button

Microprocessor: SyncMOS 8-bit, 11 MHz, 64KB FLASH memory

Wiring: Screw type terminal blocks (16 AWG max) and RJ45 modular jack

Dimensions: 82 mm x 126 mm (3.23" x 4.96" )

Weight: 0.1 kg (0.22 lb)

Environment: 0-50 °C (32-122 °F)

Mounting: Standard electrical box 2" x 4"

### Compliance

- FCC Compliant to CFR47, Part 15, Subpart B, Class B
- Industry Canada (IC) Compliant to ICES-003, Issue 5: CAN ICES-3 (B)/NMB-3(B)
- RoHS Directive (2002/95/EC)

This device complies with Part 15 of the FCC Rules. Operation is subject to the following two conditions: (1) this device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

Caution: Any changes or modifications not approved by ProLon can void the user's authority to operate the equipment.

Note: This equipment has been tested and found to comply with the limits for a Class B digital device, pursuant to part 15 of the FCC Rules. These limits are designed to provide reasonable protection against

harmful interference in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. However, there is no guarantee that interference will not occur in a particular installation. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try to correct the interference by one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and receiver.
- Connect the equipment into an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

This Class (B) digital apparatus meets all the requirements of the Canadian Interference-Causing Equipment regulations.